

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 101578
 Permit No. _____
 Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55634

1. OWNER **Curtis & Sally Kull**
 MAILING ADDRESS 428 W. 6th Street
Winnemucca, NV 89445 03

ADDRESS AT WELL LOCATION Morning Dove
Winnemucca, NV 89445

2. LOCATION SE 1/4 ~~NE~~ 1/4 Sec 33 T 36 N R 38 E Humboldt County
 PERMIT NO. NW 10-671-23 39 **Water Canyon Estates**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulder & Sand		0	20	20
Cobles and Sand		20	110	80
Sand & Clay		110	130	20
Cobles & Sand		130	180	50
Sand & Gravel	x	180	195	15
Boulders		195	260	65
Clay w/ Gravel		260	270	10
Sand	x	270	280	10
Clay w/ Gravel		280	300	20

~~N40°, 07.319'~~
W 118°, 30.883'
Elevation 3940

N 40° 56.442
W 117° 41.463
elw 3104

W 65 84

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches 0 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>188</u>	<u>+1</u>	<u>300</u>

Perforations:
 Type perforation **Factory cut**
 Size perforation **3/32x4**
 From 180 feet to 200 feet
 From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 56' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 56 feet to 300 feet

9. WATER LEVEL
 Static water level 155 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I
 Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started June 15, 20 06
 Date completed June 18, 20 06

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
			<u>4</u>

STATE ENGINEERS OFFICE
 2005 AUG 11 AM 11:46
 RECEIVED

Name **Fred Anderson & Sons Drilling, Inc.**
 (CONTRACTOR)
 Address 10760 Grass Valley Road
 (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed _____
 By driller performing actual drilling on site or contractor
 Date July 7, 2006