


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 101594
 Permit No. _____
 Basin 162



NOTICE OF INTENT NO. **30395**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER VINCE DALY ADDRESS AT WELL LOCATION 2911 W SUNSET ST
 MAILING ADDRESS 2911 W SUNSET ST
PAHRUMP, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 31 T 19S N/S R 53E E NYE County
 PERMIT NO. 28-212-03 Parcel No. BELL VISTA UNIT 1 Subdivision Name
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	67	67
CALICHE	WB	67	71	4
CLAY		71	82	11
CALICHE	WB	82	96	14
CLAY		96	115	19
CALICHE	WB	115	126	11
CLAY		126	149	23
CALICHE	WB	149	152	3
CLAY		152	176	24
CALICHE	WB	176	184	8
CLAY		184	200	16

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
 From 0 Feet To 200 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From <u>140</u> feet to <u>200</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F. Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address 1220 E MANSE RD Contractor
PAHRUMP, NV, 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed [Signature] By driller performing actual drilling on-site or contractor
 Date 11/10/2006

Date started 11/9/2006
 Date completed 11/6/2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DNRR/DWR
 RECEIVED

NOV 15 2006

LAS VEGAS OFFICE