WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101601
Permit No.
Basin 162

NOTICE OF INTENT NO. 30397

1. OWNER RON MURPHY
MAILING ADDRESS 300' W.OF CRANE SUMMIT & CABIN CANYON
LOVELL CANYON, NV

ADDRESS AT WELL LOCATION 300' W OF CRANE SUMMIT & CABIN CANYON RD

2. LOCATION SW 1/4 SW 1/4 Sec. 31 T 20S N/S R 57E E CLARK County
PERMIT NO. (Issued by Water Resources) | Parcel No. 135-31-401-020 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT & ROCK		0	8	8
SHALE		8	44	36
FRACTURED LIMESTOME	WB	44	50	6
FRACTURED SHALE		50	118	68
LIMESTONE	WB	118	125	7
SHALE		125	200	75
FRACTURED LIME STONE	WB	200	260	60

DCNR/DWR
RECEIVED
NOV 15 2006
LAS VEGAS OFFICE

Date started 10/31/2006, 19__
Date completed 11/7/2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9.5	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.36	.248	0	260

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From		feet to	feet
From	120	feet to	140 feet
From	160	feet to	180 feet
From	200	feet to	220 feet
From	240	feet to	260 feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 41 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 11/9/2006

USE ADDITIONAL SHEETS IF NECESSARY