COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101613
Permit No.
Basin 103

NOTICE OF INTENT NO. 56748

1. OWNER BLAIN MCGUIRE CONSTRUCTION
MAILING ADDRESS 2110 EASTLAKE BLVD
CARSON CITY 89705

ADDRESS AT WELL LOCATION 5951 PURSEA RD
CARSON CITY , NV 89703

2. LOCATION NE ¼ NE ¼ Sec 23 T 15 N R 20 E CARSON County

PERMIT NO. (Issued by Water Resources) | 010-087-11 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	5	5
COURSE DG SANDS		5	72	67
VOLCANIC SANDS		72	125	53
LOSS CURRCULATION		125		
AIR DRILLED				
VOLCANIC GRAVELS	XXX	125	160	35

39.15504°N
[illegible]
[illegible]

GPS INFO: NAD83
39.15504*N
119.70028*W

Date started 9/18 , 20 06
Date completed 9/20 , 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	45	3 HRS

STATE ENGINEER
2006 OCT 18 AM 11:46
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 160' Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	+2 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3X 3/32
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature 89 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 10/2/06