


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 101632
Permit No. _____
Basin 139

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57715

1. OWNER Idaho General Mines Inc.
MAILING ADDRESS 1770 State Road 278 Eureka NV 89316

ADDRESS AT WELL LOCATION 16 Mi. NW of Eureka, NV

2. LOCATION NE 1/4 SW 1/4 Sec 26 T 21N N/S R 51 E
PERMIT/WAIVER No. W-591
Issued by Water Resources Parcel No.

Subdivision Name: _____ County: _____
Latitude _____ UTM E 568096 NAD 27
Longitude _____ N 4389704 NAD 83/AVGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine gravel and sand; clay <15%		0	40	40
Sand and fine gravel; clay <25%	X	40	190	150
Clay (~50%) with minor gravel		190	200	10
Clay (>40%), sand, gravel		200	460	260
Clay (>70%) with minor sand		460	670	210
Gravel		670	680	10
Clay (>50%), sand, gravel		680	800	120

9. WELL CONSTRUCTION

Depth Drilled	800	Feet	Depth Cased	793	Feet
HOLE DIAMETER (BIT SIZE)					
	From	To			
18	Inches	0	Feet	50	Feet
12	Inches	50	Feet	800	Feet
	Inches		Feet		Feet

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14			-0.5	50
8			-1	793

Date started: 28-May, 2006
Date completed: 20-Aug, 2006

Perforations:
Type of perforation Vertical saw slots
Size of perforation 1/8 inch x 3 inch, 12 slots per foot
From 73 feet to 793 feet
From _____ feet to _____ feet

Annual Seal: Yes No
 Neat Cement 0 to 50 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 50 to 800 Pumped Poured
Type: _____
Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

7. Water Level
Static water level: 93.3 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 68 °F
Quality: _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Stewart Brothers Drilling Company
Contractor
Address #8 CR3008 Aztec, NM 87410
Contractor
Nevada contractor's license number _____
issued by the State Contractor's Board 26661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1631
Signed Stewart McLeod
By driller performing actual drilling on site or contractor
Date 9/10/2006

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>420</u>	<u>60</u>	<u>2</u>
	<u>480</u>	<u>92</u>	<u>1.5</u>
	<u>410</u>	<u>58</u>	<u>2</u>