

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58299

1. OWNER Jawaker / Turbide ADDRESS AT WELL LOCATION 243 Peach
 MAILING ADDRESS _____
 2. LOCATION SW NW SE 12 1/4 Sec. 3 T. 12 N/S R. 19 E. Dough County
 PERMIT NO. 129-03-001-045 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DG</u>		<u>0</u>	<u>115</u>	<u>115</u>
<u>DG of m.c.f. covered</u>		<u>115</u>	<u>143</u>	<u>28</u>
<u>Gravel</u>				
<u>Boulder - DG - Gravel</u>		<u>143</u>	<u>147</u>	<u>3</u>
<u>DG - Gravel</u>		<u>147</u>	<u>160</u>	<u>13</u>
<u>Boulder - DG - Gravel</u>		<u>160</u>	<u>166</u>	<u>6</u>
<u>DG - Gravel</u>		<u>166</u>	<u>205</u>	<u>39</u>
<u>Boulder - DG - Gravel</u>		<u>205</u>	<u>203</u>	<u>8</u>
<u>DG - Gravel</u>		<u>203</u>	<u>240</u>	<u>27</u>

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 240 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1.88</u>	<u>+1</u>	<u>20</u>
<u>6 5/8</u>		<u>SDR 21</u>	<u>20</u>	<u>240</u>

Perforations:
 Type perforation Grinder cut
 Size perforation 1/8 inch
 From 200 feet to 240 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 240 feet

Date started 7-10, 2006
 Date completed 7-11, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		<u>4 hrs</u>

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow NA G.P.M. 257 P.S.I.
 Water temperature 60d °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255 Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 2321
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-17-06