WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101656
Permit No.
Basin 087

NOTICE OF INTENT NO. 57814

1. OWNER Linscott Properties LTD
MAILING ADDRESS 12245 S. Virginia St.
Reno, NV 89511

ADDRESS AT WELL LOCATION 12245 S. Virginia St.

2. LOCATION SW 1/4 SE 1/4 Sec. 17 T 18N N/S R 20E E Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. 044-320-45 | Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
We abandoned this well after trying to perforate the well for about 7 hours. We finally perforated from 60' to 40' and about 12-15 perforations in that zone. We were unable to perforate higher. The casing was .280 and had an internal coragaded attached metal casing insert that prevented additional perforations. We used a Mills Knife. We then pumped approximately 1.5 cu. yards of neat cement mixed 5.2 gal/sack from bottom to top using tremie pipe. This was approved by Ryan Clark.				
Washoe Permit #WL060152				
NAD83				
N 39.42066				
W 119.75979				

Date started 8/29/2006 , 19__
Date completed 8/30/2006 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	21	3	72 hrs

8. WELL CONSTRUCTION
Depth Drilled 78 Feet Depth Cased 78 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~6 1/2	19	.280	0	78

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 60 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 78
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 8/30/2006

USE ADDITIONAL SHEETS IF NECESSARY