

Log No. 101674
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. SP272

1. OWNER Casey JONES ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ ADDRESS GRANNY RD
NE 286 Smith Gage RD
 2. LOCATION SW 1/4 NB 1/4 Sec. 35 T. 11 N/S R. 23 E. LYON County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DIRT</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>COBBLES</u>		<u>6</u>	<u>35</u>	<u>29</u>
<u>BROWN CLAY-ROCK</u>		<u>35</u>	<u>78</u>	<u>43</u>
<u>BROWN STICKY CLAY</u>		<u>78</u>	<u>126</u>	<u>48</u>
<u>BROWN CLAY-GRAVEL</u>		<u>126</u>	<u>140</u>	<u>14</u>
<u>MEDIUM GRAVEL</u>		<u>140</u>	<u>175</u>	<u>35</u>

38.77922 N
 119.36625 W
 NAD83

RECEIVED
 2006 AUG 22 PM 2:33
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 175 Feet Depth Cased 175 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 175 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>1.88</u>	<u>71</u>	<u>15</u>
<u>6 3/8</u>	<u>4</u>	<u>SBR21</u>	<u>15</u>	<u>175</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation 1.045" X 4"
 From _____ feet to _____ feet
 From 145 feet to 175 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 106 ft
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 106 feet to 175 feet

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255
Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Watson
 By driller performing actual drilling on site or contractor
 Date 14 JUN 06

Date started 6 JUN, 2006
 Date completed 7 JUN, 2006

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25+</u>		<u>1.0</u>	