



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. SP587

1. OWNER Matt Triglia ADDRESS AT WELL LOCATION 1856 FLSH SPRINGS
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SW 1/4 Sec. 01 T. 12 N/S R. 20 E Douglas County
 PERMIT NO. 1220-01-001-075 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT-GRAVEL		0	6	6
BROWN CLAY-GRAVEL		6	115	109
BROWN STICKY CLAY		115	122	7
COBBLES	X	122	135	13
BROWN CLAY		135	155	20
BROWN CLAY-GRAVEL	X	155	215	60
LARGE GRAVEL	X	215	250	35

38,93727 N
 11969122 W
 2006 AUG 22 PM 2:33
 STATE ENGINEERS OF NV
 MAD 83

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches _____ Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>10</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>10</u>	<u>250</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation .045" X 4"
 From _____ feet to _____ feet
 From 210 feet to 250 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 ft Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 53 feet to 250 feet

9. WATER LEVEL
 Static water level 74 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

Date started 15 JUN, 2006
 Date completed 16 JUN, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		<u>2.0</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255 Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date 18 JUN 06