

Log No. 101706  
Permit No. \_\_\_\_\_  
Basin 212

09562  
PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

6 WEEKS

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30660

1. OWNER JASON HOORN ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 259 N. Pecos STE 100 1600 PALME SPRINGS  
HENDERSON NV HENDERSON NV.  
2. LOCATION E 1/4 1/4 NW 1/4 Sec. 9 T. 22 N/S R. 62 E CLARK County  
PERMIT NO. 178-09-118-000 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty SAND		0.0	2.5	2.5
CAUCCI		2.5	4.0	1.5
SILTY CLAY		4.0	9.0	5.0
CLAY w/ CAUCCI NODDLES		9.0	10.0	1.0
CLAY		10.0	14.0	4.0
SANDY CLAY		14.0	19.0	5.0
SILTY CLAY		19.0	22.0	3.0
SANDY GRAVEL		22.0	26.0	4.0
CLAY		26.0	31.5	5.5

map Datum WGS 84  
36° 03.347'N 115° 03.528'W  
36° 03.336'N 115° 03.489'W  
36° 03.348'N 115° 03.439'W  
36° 03.283'N 115° 03.481'W  
36° 03.301'N 115° 03.460'W  
36° 03.391'N 115° 03.498'W

8. WELL CONSTRUCTION  
Depth Drilled 31.5 Feet Depth Cased 31.5 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
8 1/2 Inches 0.0 Feet 31.5 Feet  
8 1/2 Inches 0.0 Feet 20.0 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.0</u>		<u>SEA 40 PVC</u>	<u>0.0</u>	<u>31.5</u>
<u>2.0</u>		<u>SEA 40 PVC</u>	<u>0.0</u>	<u>20.0</u>

Perforations:  
Type perforation MACHINE SECT  
Size perforation .020  
From 31.5 feet to 21.5 feet  
From 20.0 feet to 15.0 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 1'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 31.5 / 20.0 feet to 19.5 / 13.0 feet

9. WATER LEVEL  
Static water level 27 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name FABLE DRILLING SERVICES LLC Contractor  
Address 7150 PLAIN ST. Contractor  
LAS VEGAS, NV. 89119  
Nevada contractor's license number issued by the State Contractor's Board 51266  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2222  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 11/16/06

Date started 10/24, 2006  
Date completed 10/27, 2006

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)