



095602
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

6 WELLS

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30661

1. OWNER JASON HOORN ADDRESS AT WELL LOCATION 1600 AZULE SPRINGS
 MAILING ADDRESS 259 N. PECOS RD STE 100 HENDERSON, NV.
 2. LOCATION E 1/2 1/4 NW 1/4 Sec. 9 T. 22 N/S R. 62 E CLARK County
 PERMIT NO. 178-09-118-000 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MAN

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SIXTY SAND</u>		<u>0.0</u>	<u>2.5</u>	<u>2.5</u>
<u>GRAVEL</u>		<u>2.5</u>	<u>4.0</u>	<u>1.5</u>
<u>SIXTY CLAY</u>		<u>4.0</u>	<u>9.0</u>	<u>5.0</u>
<u>CLAY W/ GRAVEL</u>		<u>9.0</u>	<u>10.0</u>	<u>1.0</u>
<u>CLAY</u>		<u>10.0</u>	<u>14.0</u>	<u>4.0</u>
<u>SANDY CLAY</u>		<u>14.0</u>	<u>19.0</u>	<u>5.0</u>
<u>SIXTY CLAY</u>		<u>19.0</u>	<u>25.0</u>	<u>6.0</u>
<u>MAP DATUM W6584</u>				
<u>36° 03.344 N 115° 03.522 W</u>				
<u>36° 03.337 N 115° 03.489 W</u>				
<u>36° 03.351 N 115° 03.437 W</u>				
<u>36° 03.283 N 115° 03.432 W</u>				
<u>36° 03.302 N 115° 03.462 W</u>				
<u>36° 03.291 N 115° 03.450 W</u>				

8. WELL CONSTRUCTION
 Depth Drilled 25.0 Feet Depth Cased 25.0 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
8 1/2 Inches 0.0 Feet 25.0 Feet
8 1/2 Inches 0.0 Feet 10.0 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.0</u>		<u>5CH 40 PVC</u>	<u>0.0</u>	<u>25.0</u>
<u>2.0</u>		<u>5CH 40 PVC</u>	<u>0.0</u>	<u>10.0</u>

Perforations:
 Type perforation MACHINE SLOT
 Size perforation 1.000
 From 25.0 feet to 15.0 feet
 From 10.0 feet to 5.0 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 1' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 25/10 feet to 13/3 feet

9. WATER LEVEL
 Static water level 16 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ETABLE DRILLING SERVICES LLC Contractor
 Address 7150 PLACID ST Contractor
LAS VEGAS NV 89119
 Nevada contractor's license number issued by the State Contractor's Board 51266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11/16/06

Date started 10/24, 2006
 Date completed 10/27, 2006

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	