WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

095602

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

6 WELLS

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101712
Permit No.
Basin 2.2

NOTICE OF INTENT NO. 30661

1. OWNER JASON HOGRN
MAILING ADDRESS 259 N. PECOS RD STE 100
HENDERSON NV.

ADDRESS AT WELL LOCATION 1600 AZURE SPRINGS
HENDERSON, NV.

2. LOCATION E 1/2 1/4 NW 1/4 Sec. 9 T. 22 N/S R. 62 E. CLARK County
PERMIT NO. Issued by Water Resources | 178-09-118-000 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0.0	2.5	2.5
GRAVEL		2.5	4.0	1.5
SILTY CLAY		4.0	9.0	5.0
CLAY W/GRAVEL		9.0	10.0	1.0
CLAY		10.0	14.0	4.0
SANDY CLAY		14.0	19.0	5.0
SILTY CLAY		19.0	25.0	6.0

MAP DATUM WGS84

36° 03.344 N 115° 03.522 W

36° 03.337 N 115° 03.487 W

36° 03.351 N 115° 03.437 W

36° 03.283 N 115° 03.432 W

36° 03.302 N 115° 03.462 W

36° 03.291 N 115° 03.450 W

DCNR/DWR
RECEIVED
NOV 20 2006
LAS VEGAS OFFICE

Date started 10/24, 2006
Date completed 10/27, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25.0 Feet Depth Cased 25.0 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8 1/2	Inches	0.0	Feet	25.0	Feet
8 1/2	Inches	0.0	Feet	10.0	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0		SCH 40 PVC	0.0	25.0
2.0		SCH 40 PVC	0.0	10.0

Perforations:
Type perforation MACHINE SLOT
Size perforation .020
From 25.0 feet to 15.0 feet
From 10.0 feet to 5.0 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25/10 feet to 13/3 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING SERVICES LLC (Contractor)
Address 7150 PLACID ST (Contractor)
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
Signed (By driller performing actual drilling on site or contractor)
Date 11/16/06

(Rev 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627