



OFFICE USE ONLY
 Log No. 101795
 Permit No. _____
 Basin 230

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29873

1. OWNER Otilio Gamboa ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6017 Monte Bay 1865 S. Desert Storm Dr.
Las Vegas, Nv. 89108 Amargosa Valley, Nv. 89020
 2. LOCATION NE 1/4 SE 1/4 Sec. 12 T. 17 N. R. 48 E. Nye County
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Monitor Stock Irrigation Test Air Other _____
 5. WELL TYPE Cable Rotary RVC Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel w/ sand		0	75	75
limestone		75	80	5
gravel w/ sand	1st	80	95	15
limestone		95	100	5
sand w/ clay layers		100	135	35
white clay w/ limestone layers		135	200	65
Bottom of well			200	

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	200
8	steel	.188		7

 Surface Protective Casing: _____
 Perforations:
 Type perforation Machined
 Size perforation 4R, 1/2" x 3" every 12"
 From 100 feet to 140 feet
 From 160 feet to 190 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

DCNR/DWR
 RECEIVED

DEC 05 2006

LAS VEGAS OFFICE

Date started 10/25/06
 Date completed 10/28/06

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Cook Drilling Co. Contractor
 Address H.C. 70 Box 544543 Contractor
Amargosa Valley, Nv. 89020
 Nevada contractor's license number issued by the State Contractor's Board 5376-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 22160
 Signed Randy Johnson
 By driller performing actual drilling on site or contractor
 Date 10/25/06