


OFFICE USE ONLY
 Log No. 101839
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30417

1. OWNER JAMES BUYERS
 MAILING ADDRESS 2871 E. ROCKIN DOC
PAHRUMP, NV

ADDRESS AT WELL LOCATION 2871 E. ROCKIN DOC

2. LOCATION NE 1/4 SE 1/4 Sec. 12 T 21S
 PERMIT NO. 44-531-27
Issued by Water Resources Parcel No.

N/S R 53E E NYE County
 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------|--------------|------|-----|------------|
| CLAY | | 0 | 62 | 62 |
| CALICHE | WB | 62 | 64 | 2 |
| CLAY | | 64 | 83 | 19 |
| CALICHE | WB | 83 | 94 | 11 |
| CLAY | | 94 | 117 | 23 |
| CALICHE | WB | 117 | 121 | 4 |
| CLAY | | 121 | 143 | 22 |
| CALICHE | WB | 143 | 154 | 11 |
| CLAY | | 154 | 171 | 17 |
| CALICHE | WB | 171 | 194 | 23 |
| CLAY | | 194 | 200 | 6 |

**DCNR/DWR
 RECEIVED
 DEC 21 2006**

LAS VEGAS OFFICE

Date started 12/18/2006, 19
 Date completed 12/18/2006, 19

7. WELL TEST DATA

| TEST METHOD: | <input type="checkbox"/> Bailer | <input type="checkbox"/> Pump | <input type="checkbox"/> Air Lift |
|--------------|---------------------------------|-------------------------------|-----------------------------------|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| | | | |
| | | | |
| | | | |

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From | Feet | To | Feet |
|--------|------|------|-----|------|
| 10 | 0 | 0 | 200 | 200 |
| | | | | |
| | | | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|--------------------|-------------------------|-------------|-----------|
| 6 | 3.63 | .250 | 0 | 200 |

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3
 From 140 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL

Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor
 Address 1220 E. MANSE RD
Contractor
PAHRUMP, NV, 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan
By driller performing actual drilling on-site or contractor
 Date 12/19/2006