


PUMPS
FOUNDATION DRILLING
DE-WATERING SPECIALISTS

Allen Drilling Inc.

GENERAL ENGINEERING CONTRACTOR
FAX # 736-3112

4847 VALLEY VIEW BLVD.
LAS VEGAS, NEVADA 89103
736-7366



December 2, 1991

Division of Water Resource
Mail Room Complex
Las Vegas, Nevada 89158

Well # 1 Log # 101843
Well # 2 Log # 101844
Well # 3 Log # 101845

Attn: Dean Goodall

Dear Mr. Goodall,

On November 21, 1991, we plugged three wells for Richardson Construction at Jack Dailey Elementary School. Well #1 was 32' deep with 6" steel casing and a static water level of 10' feet. It took 1/3 yard of neat cement. Well #2 was an unknown depth with a blockage at 33' deep with 6" steel casing and a static water level of 10 feet. It took 3/4 yard of neat cement. Well #3 was 175' deep with 8" steel casing and a static water level 10 feet. We perforated the well from 50 feet to 175 feet and it took 4 yards of neat cement.

Respectfully,

Gina Bridenbaker
Gina Bridenbaker

DSB
2001 E Reno Ave

(702) 799 5690

162-26-601-001

215-61E-26

RECEIVED

DEC 04 1991

Div. of Water Resources
Branch Office - Las Vegas, NV