Allen Drilling Inc.
GENERAL ENGINEERING CONTRACTOR
FAX # 736-3112

PUMPS
FOUNDATION DRILLING
DE-WATERING SPECIALISTS

4847 VALLEY VIEW BLVD.
LAS VEGAS, NEVADA 89103
736-7366

June 4, 1991

Division of Water Resources

Attn: Dean Goodall

Dear Mr. Goodall,

During the week of May 13-17, 1991 we plugged 11 abandon wells at various locations for Rock Breakers Inc.

#1 well Procyon 1 block south of Sunset, legal NW 1/4, NW 1/4, sec 5, Township 22S, R 61E. 8 5/8" casing, 250' deep, static water level 210', the well was perforated from bottom up and took 3 3/4 yards of 9 sac neat cement slurry pumped from bottom up. Log# 101846

#2 Escondido south of Sunset legal NW 1/4, NW 1/4, Sec 2, T 22s, R 61E, 8 5/8" casing, 250' deep, static water level 55', the well was perforated from bottom up and took 3 3/4 yards of 9 sac neat slurry pumped form bottom up. Log# 101847

#3 Well Escondido south of Sunset, legal NW 1/4, NW 1/4, Sec 2, T 22s, R 61E 8 5/8" casing, 83' deep, static water level 49', the well was perforated from bottom up and took 1 1/4 yards of 9 sac neat cement slurry pumped from bottom up. Log# 101848

#4 well Escondido and Sunset, legal NW 1/4, NW 1/4, Sec 2, T 22s, R 61 E, 8 5/8" casing, 78' deep, static water level 55', the well was perforated from bottom up and took 1 1/4 yards of 9 sac neat cement slurry pumped from bottom up. Log# 101849

#5 well Maryland Pkwy and Russell, legal SW 1/4, SW 1/4, Sec 26, T 22s, R 61E, 8 5/8" casing, 182' deep, static water level 66', the well was perforated form bottom up and took 2 3/4 yards of 9 sac neat cement slurry pumped from bottom up. Log# 101850

#6 Well Maryland Pkwy and Russell, legal SW 1/4, SW 1/4, Sec 26, T 22s, R 61E, 8 5/8" casing, 137' deep, static water level 50', the well was perforated from bottom up and took 2 yards of 9 sac neat cement slurry pumped from bottom up. Log# 101851

Cont-

RECEIVED
JUN 04 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Allen Drilling Inc.
PUMPS
FOUNDATION DRILLING
DE-WATERING SPECIALISTS
GENERAL ENGINEERING CONTRACTOR
FAX # 736-3112
4847 VALLEY VIEW BLVD.
LAS VEGAS, NEVADA 89103
736-7366

June 4, 1991

pg 2.

#7 Well Hacienda and Giles, legal SW 1/4, NW 1/4, Sec 28, T 21S, R 61E, 8 5/8" casing 125' deep, static water level 45', the well was perforated from bottom up and took 1 3/4 yards of 9 sac neat cement slurry pumped from bottom up. Log# 101852

#8 Well Hacienda & Giles, legal SW 1/4, NW 1/4, Sec 28, T 21s, R 61E, 8 5/8" casing, 65' deep, static water level 40', and took 3/4 yards of 9 sac neat cement slurry. Log# 101853

#9 Well Hacienda & Haven, legal NW 1/4, SE 1/4, Sec 28, T 21s, R 61E 8 5/8" casing, 48' deep, static water level 44' and took 1/2 yard of 9 sac neat cement slurry. Log# 101854

#10 Well, Hacienda & Haven, legal NE 1/4, SE 1/4, Sec 28, T 21s, R 61E 8 5/8" casing, 118' deep, static water level 33', the well was perforated from bottom up and took 1 3/4 yards of 9 sac neat cement slurry pumped from bottom up. Log# 101855

#11 Well, Hacienda & Haven, legal NE 1/4, SE 1/4, Sec 28, T 21s, R 61E 8 5/8" casing, 96' deep, static water level 38', the well was perforated from bottom up and took 1 1/2 yards of 9 sac neat cement slurry pumped from bottom up. Log# 101856

If any additional information is needed please feel free to call our office.

Respectfully,

Fred B. Allen III

Fred B. Allen, III

FBA/gb

Copy: Rock Breakers Inc.
5541 So. Cameron
Las Vegas, NV. 89118