COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101944
Permit No.
Basin 104

NOTICE OF INTENT NO. 58235

1. OWNER CARSON CITY PARKS DEPARTMENT
MAILING ADDRESS 3303 BUTTI WAY BUILDING # 9
CARSON CITY , NV 89701

ADDRESS AT WELL LOCATION 5300 KINGS CANYON RD
CARSON CITY , NV 89701

2. LOCATION SE ¼ SE ¼ Sec 22 T 15 N R 19 E CARSON County

PERMIT NO. (Issued by Water Resources) 007-061-41 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Set up over old 6 5/8 well				
fished out old pump that				
was dropped in bottom				
perforated from 210' to				
260'				
trimmie 1 1/4 pipe to				
bottom and pumped with				
neat cement to surface				
39.144221				
119.828494 NAD27				
GPS INFO:				
39.14413*N				
119.82951*W NAD83				
6 yrds Neat Cement				

RECEIVED 2007 JAN -3 AM 11:27 STATE ENGINEERS OFFICE

Date started 12/15 , 20 06
Date completed 12/15 , 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A	N/A	N/A

8. WELL CONSTRUCTION
Depth Drilled N/A Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

	From	To
N/A Inches	N/A Feet	N/A Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.86	.156	0	360

Perforations:
Type perforation HOLTE PERPORATOR
Size perforation
From 260 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 50+
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 365 feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

9. WATER LEVEL
Static water level 300' feet below land surface
Artesian flow G.P.M P.S.I
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael Hack
By driller performing actual drilling on site or contractor
Date 12/21/06

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429