

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 101949

Permit No. \_\_\_\_\_

Basin 092B

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **58963**

1. OWNER Dan Turner ADDRESS AT WELL LOCATION 11975 Heartpine  
 MAILING ADDRESS Hibernica Lane  
Sparks, NV 89436

2. LOCATION SW 1/4 NW 1/4 Sec. 15 T 21N N/S R 19E E Washoe County  
 PERMIT NO. 080-356-06 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we perforated the well from 180'-160'. We then perforated from 250'-210'. We abandoned this well by pumping approximately 3.25 cu. yards of neat cement mixed 5.2 gal/sack from bottom to top using tremie pipe.				
Washoe Co. Permit #060180				
NAD83				
N39.68772				
W119.84510				
39.687811 N				
119.844073 W NAD22				

8. WELL CONSTRUCTION  
 Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0 Feet	50 Feet
8 5/8" Inches	50 Feet	210 Feet
6 1/8" Inches	210 Feet	275 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	210
5	10	.137	210	275

Perforations:

Type perforation Factory  
 Size perforation 3/32 x 3"

From	160 feet to	180 feet
From	210 feet to	250 feet
From	180 feet to	200 feet
From	248 feet to	275 feet
From	feet to	feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 210 feet

9. WATER LEVEL  
 Static water level 214 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2299  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor  
 Date 10/24/2006

Date started 10/23/2006, 19  
 Date completed 10/24/2006, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
Pump	6	8	1 hr