

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 101950  
 Permit No. \_\_\_\_\_  
 Basin 104

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **57815**

1. OWNER **Clyde Lippincott** ADDRESS AT WELL LOCATION **870 E. Overland St.**  
 MAILING ADDRESS **870 E. Overland St.**  
**Carson City, NV 89701**

2. LOCATION **SW NW 1/4 NE 1/4 Sec. 32 T 15N N/S R 20E E Carson** County  
 PERMIT NO. **58737** Parcel No. **009-182-09** Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **Mud**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
Rusty Granite				
Sands/clay		1	36	35
Granite sands, w/clay streaks		36	53	17
Sandy Brown Clay		53	65	12
Rusty Granite sands		65	94	29
Brown sandy clay		94	108	14
Rusty Brown granite/sands		108	124	16
Brown sandy clays		124	133	9
Rusty granite/sands		133	151	18
Brown rusty clay		151	153	2
Granite sands		153	157	4
Soft zone	x	157	159	2
Weathered granite/sands w/clay streaks	x?	159	194	35
Soft zone	x?	194	197	3
Weathered Granite		197	221	24
Soft zone	x?	221	226	5
Rusty brown granite/sands	x?	226	239	13
Weathered granite	x	239	245	6
Fracture	x	245	246	1
Weathered Granite		246	250	4
Carson Permit #06001227				
NAD83				
N39.12683	39.12683			
W119.75902	119.75902			

8. WELL CONSTRUCTION  
 Depth Drilled **250** Feet Depth Cased **250** Feet

HOLE DIAMETER (BIT SIZE)  
**10 5/8** Inches From **0** Feet To **250** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>12.92</b>	<b>.188</b>	<b>+1</b>	<b>250</b>

Perforations:  
 Type perforation **Factory**  
 Size perforation **3/32 x 3"**  
 From **150** feet to **170** feet  
 From **190** feet to **250** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **53**  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **53** feet to **250** feet

9. WATER LEVEL  
 Static water level **35** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cold** °F Quality **not tested**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Bruce MacKay Pump & Well Service, Inc.** Contractor  
 Address **1600 Mt. Rose Hwy** Contractor

Date started **10/10/2006**, 19\_\_\_\_\_  
 Date completed **10/17/2006**, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<b>Air</b>	<b>40+</b>	<b>3 hrs</b>	

**Reno, NV 89511**  
 Nevada contractor's license number issued by the State Contractor's Board **23096**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **923**  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor  
 Date **10/20/2006**