WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101955
Permit No.
Basin 087

NOTICE OF INTENT NO. 59079

1. OWNER Nevada Bell
MAILING ADDRESS 2600 Camino Ramon 3E401
San Ramon, CA 94583

ADDRESS AT WELL LOCATION 195 E 1st Street Reno

2. LOCATION NE 1/4 SE 1/4 Sec. 11 T 19N N/S R 19E E Washoe County
PERMIT NO. ~~1749 & R-537~~ (Issued by Water Resources) | 011-420-01 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we cut a turbine pump and let it fall to bottom of the well. We then abandoned a 10" x 352' well by pumping 9 cubic yards of neat cement from the bottom to 30' using tremie pipe. We then pumped the water off the top of the cement and poured 1 cubic yard of neat cement to the top of the well.				
Washoe County Permit # WL 060232				
NAD 83				
N 39.52670				
W 119.81107				
11S0258476				
UTM4378803 NAD27				
39.526789 N				
119.810045 W NAD27				

Date started 12/7/2006 , 19__
Date completed 12/20/2006 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2006 DEC 29 PM 2:19
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 352 Feet Depth Cased 352 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		8 Gauge	0	352

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 21 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2159
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 12/20/2006

USE ADDITIONAL SHEETS IF NECESSARY