WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101963
Permit No. 559~~8~~20
Basin 209

NOTICE OF INTENT NO. 30886

1. OWNER Kent Whipple Ranch
MAILING ADDRESS HCR 61 Box 27 Hiko, Nevada 89017 NE
ADDRESS AT WELL LOCATION 5 miles north of Alamo by Hywy 93
19 (TDA) 8/26/09

2. LOCATION SE ¼ ~~SE~~ ¼ Sec. ~~18~~ T. 6 N/S R. 61 E. Lincoln County
PERMIT NO. 559~~8~~20 (Issued by Water Resources) 11-160-24 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil + Sand		0	37	37
Cemented Gravel		37	82	45
Sand + Gravel		82	116	34
Sand + Clay		116	159	43
Clay + Gravel		159	191	32
Cemented Gravel		191	266	75
Clay + Cemented Gravel		266	300	34

GPS 37.415 039° N
115.176 649° W NAD 27 ✓

corrections as per POC submissions. See photos in Permit file. -swazlian- 3/30/09

Date started 12-14, 2006
Date completed 12-17, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2007 JAN 10 AM 11:09
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
15 Inches	0 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8			0	300

Perforations:
Type perforation Factory
Size perforation
From 120 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 300 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C. Water Wells + Pump Service (Contractor)
Address 2870 W. Pebble Rd. (Contractor)
Las Vegas, NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316
Signed [signature] By driller performing actual drilling on site or contractor
Date 12-18-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627