

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 101965
Permit No. 55920 73719 (PS)
Basin 209 79132

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30885

1. OWNER Kent Whipple Ranch
MAILING ADDRESS HCR 61 Box 27 Hiko, Nevada 89017
ADDRESS AT WELL LOCATION 5 miles North of Alamo of Hwy 93

2. LOCATION SE NW 1/4 Sec. 18 T. 6 R. 61 E. Lincoln County
PERMIT NO. 55920 73719 11-160-24
Issued by Water Resources (PS) Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary PVC
 Air Other Manual

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil + Sand		0	20	20
Cemented Gravel		20	26	6
White Clay		26	237	211
Clay + Gravel		237	249	12
Cemented Gravel		249	300	51

37' GPS: 32.427, 539° N
115.197, 760° W NAD 27

All corrections as per PDC submission
and photos submitted 3/30/09
-S. J. W. L. com-

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet
HOLE DIAMETER (BIT SIZE)
From 20 Inches To 300 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12			0	300

Perforations:
Type perforation Factory
Size perforation
From 120 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 100 feet to 300 feet

9. WATER LEVEL
Static water level 37 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

Date started 12-19, 2006
Date completed 12-21, 2006

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
Draw Down (Feet Below Static)			
Time (Hours)			

60:11 HV 01 NOV 2007
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C. Water Wells + Pump Service Contractor
Address 2870 W. Pebble Rd. Contractor
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316
Signed [Signature] By driller performing actual drilling on site or contractor
Date 12-21-06