WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102063
Permit No.
Basin 162

NOTICE OF INTENT NO. 30418

1. OWNER STEVE ROSE
MAILING ADDRESS 5701 MARY LOU
PAHRUMP, NV

ADDRESS AT WELL LOCATION 5701 MARY LOU

2. LOCATION SW 1/4 NE 1/4 Sec. 16 T 21S N/S R 54E E NYE County
PERMIT NO. (Issued by Water Resources) 43-113-11 (Parcel No.) COTTONWOODS AT HAFEN RANCH (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DIRT & ROCK | | 0 | 20 | 20 |
| SILT & ROCK | | 20 | 79 | 59 |
| SAND & GRAVEL | WB | 79 | 84 | 5 |
| CLAY & ROCK | | 84 | 110 | 26 |
| SILT WITH LAYERS OF | WB | 110 | | |
| GRAVEL | | | 180 | 70 |
| CLAY | | 180 | 190 | 10 |
| SAND & GRAVEL | WB | 190 | 200 | 10 |

DCNR/DWR
RECEIVED
JAN 16 2007
LAS VEGAS OFFICE

Date started 1/10/2007 , 19__
Date completed 1/10/2007 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 200 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 3.63 | .250 | 0 | 200 |
| | | | | |
| | | | | |

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From 80 feet to 160 feet
From 100 feet to 120 feet
From 140 feet to 200 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 1/11/2007

USE ADDITIONAL SHEETS IF NECESSARY