

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29879

1. OWNER Paul Burton Jr. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 495 E. Florence Circle Amargosa Valley, Nv. 89020
Anahem Ca. 92807 N^{OR} 49 E. NYE County
 2. LOCATION SE 1/4 NE 1/4 Sec. 7 T. 17
 PERMIT NO. 19-401-48 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>snd. & gravel</u>		<u>0</u>	<u>80</u>	<u>80</u>
<u>large gravel</u>	<u>121</u>	<u>80</u>	<u>105</u>	<u>25</u>
<u>gravel w/ spd.</u>		<u>105</u>	<u>185</u>	<u>80</u>
<u>tan clay w/ snd.</u>		<u>185</u>	<u>200</u>	<u>15</u>
<u>Bottom of well</u>			<u>200</u>	

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>200</u>
<u>8</u>	<u>steel</u>	<u>.188</u>		<u>7</u>

Perforations:
 Type perforation Machined
 Size perforation 4R, 1/8" x 3" Every 12"
 From 100 feet to 120 feet
 From 140 feet to 160 feet
 From 190 feet to 190 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

DCNR/DWR
 RECEIVED
 JAN 05 2007

LAS VEGAS OFFICE

Date started 12/22, 2006
 Date completed 12/23, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 81 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Cook's Drilling Co. Contractor
 Address H.C. 70 Box 543 Contractor
Amargosa Valley, Nv. 89020
 Nevada contractor's license number issued by the State Contractor's Board 5376-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
 Signed Rod Hudson
 By driller performing actual drilling on site or contractor
 Date 1/3/06