

0036014
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

LOWEUS

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30667

1. OWNER ROSE PELINO ADDRESS AT WELL LOCATION 5164 RENT-A-CAR RD. LAS VEGAS NV
MAILING ADDRESS 6 SULLY WAY PARSIPPONY NJ
2. LOCATION SE 1/4 NW 1/4 Sec 27 T 21 N/S R. 61 E CLARK County
PERMIT NO. 162-27-201-005 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Asphaltes</u>		<u>0.0</u>	<u>0.4</u>	<u>0.4</u>
<u>Sand w/Gravel</u>		<u>0.4</u>	<u>5.0</u>	<u>4.6</u>
<u>Clayey Sand</u>		<u>5.0</u>	<u>10.0</u>	<u>5.0</u>
<u>Gravel</u>		<u>10.0</u>	<u>18.0</u>	<u>8.0</u>
<u>Silty Clay</u>		<u>18.0</u>	<u>25.0</u>	<u>7.0</u>
<u>Gravel</u>		<u>25.0</u>	<u>28.0</u>	<u>3.0</u>
<u>Clay/Silty Clay</u>		<u>28.0</u>	<u>45.0</u>	<u>17.0</u>
MAP DATUM <u>WGS 84</u>				
MNU 49 <u>36° 05' 9.42" N 115° 08' 7.62" W</u>				
MNU 44 <u>36° 05' 8.34" N 115° 09' 9.68" W</u>				
MNU 45 <u>36° 05' 8.21" N 115° 08' 9.56" W</u>				
MNU 48 <u>36° 05' 8.91" N 115° 08' 7.32" W</u>				
MNU 46 <u>36° 05' 8.11" N 115° 09' 0.22" W</u>				
MNU 47 <u>36° 05' 8.42" N 115° 09' 0.24" W</u>				
DCNR/DWR RECEIVED				
JAN 16 2007				

8. WELL CONSTRUCTION
Depth Drilled 45/30 Feet Depth Cased 45/30 Feet
HOLE DIAMETER (BIT SIZE)
From To
8 1/2 Inches 0.0 Feet 45.0 Feet
8 1/2 Inches 0.0 Feet 30.0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.0</u>		<u>SC40 PVC</u>	<u>0.0</u>	<u>45.0</u>
<u>2.0</u>		<u>SC40 PVC</u>	<u>0.0</u>	<u>30.0</u>

Perforations:
Type perforation MACHINING SECT
Size perforation 020
From 45.0 feet to 40.0 feet
From 30.0 feet to 10.0 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 1' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 45/30 feet to 30/8 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDGE DRILLING SERVICES LLC Contractor
Address 7150 PLACID ST. LAS VEGAS NV 89119 Contractor
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 01/11/07

7. LAS VEGAS WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)