



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46742
 ADDRESS AT WELL LOCATION E. Thomas Canyon R.d

1. OWNER Humboldt County ADDRESS AT WELL LOCATION E. Thomas Canyon R.d
 MAILING ADDRESS 50 W. Fifth St.
Winnemucca, N.V. 89445
 2. LOCATION SW 1/4 SE 1/4 Sec. 12 T 35 N 37 E Humboldt County
 PERMIT NO. M/0 1427 Issued by Water Resources County Right of Way Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine Silt	none	0'	2'	2'
Coarse gravel + silt	none	2'	15'	13'
Cobbles with fine sand	none	15'	20'	5'
Gravel + clay	none	20'	25'	5'
Gravel with sandy silt + clay	none	25'	35'	10'
Orangeish fine sand + clay some gravel	none	35'	75'	40'
Brown fine sand + clay some gravel	none	75'	80'	5'
Brown clay + sand	none	80'	90'	10'
Brown fine sand + clay + gravel	97'	90'	105'	15'
Orangeish brown sand + gravel	97'	105'	110'	5'

40.915213 N
 117,762357 W
 NAD 83

Northing - 15,369,238
 Easting - 2,851,292
 NAD 83

8. WELL CONSTRUCTION
 Depth Drilled 110' Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
8 Inches 0 Feet 110 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40	0'	90

Perforations:
 Type perforation Factory slot
 Size perforation .020
 From 90 feet to 110 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 86 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured 86 - 88 Concrete Grout
Bentonite chips
 Gravel Packed: Yes No
 From 88 feet to 110 feet

9. WATER LEVEL
 Static water level 9.7' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 68.5 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Haz-Tech Drilling Contractor
 Address P.O. Box 940 Meridian Contractor
10. 83680
 Nevada contractor's license number issued by the State Contractor's Board 0038018
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2246
 Signed Jordan Adams
 By driller performing actual drilling on site or contractor
 Date 10-29-06

Date started 10-25, 2006
 Date completed 10-26, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			