REPORT NO. A06.088

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 102173
PERMIT NO.
BASIN Ø83

NOTICE OF INTENT NO. 58767

1. OWNER William Bridge
MAILING ADDRESS 2176 Butler Ave, South Lake Tahoe, CA 96150

ADDRESS OF WELL 2160 Castle Peak Road
Reno, NV 89521

2. WELL LOCATION NW 1/4 NW 1/4 SEC. 29 T 18 R 21 E Storey COUNTY

PERMIT NO ____ PARCEL NO 003-331-18 SUBDIVISION NAME Highland Ranches

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Large Gray Blue VR With Black &		0		
Reddish Brown Clay VR		0	4	4
Pinkish Gray Clay VR		4	12	8
Multi Color VR Gray Clay		12	60	48
Hard VR Multi Color		60	90	30
Blue Gray VR White VR		90	110	20
Blue Green VR White		110	127	17
Large Gray Blue VR With Black &		127		
White Specs, Gray Blue Sandy Clay		127	147	20
Fractured Blue VR White Specs		147		
Yellow Specs, Gray Blue Clay		147	220	73
Hard Fractured Blue VR		220	250	30
Semi Hard Gray Blue VR W/ White		250		
Specs Some Gray Blue Clay		250	255	5
Large Gray Blue VR		255	263	8
Blue VR With White Specs, Dark		263		
Green & Blue Green VR		263	298	35

Notes : WGS-84 GPS: Latitude: N39 24.07 Longtitude: W119 39.24

39.401273 N
119.653000 W NAD27

Date Started 11/16/2006 Date Completed 11/21/2006

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1 HR

8. WELL CONSTRUCTION

Depth Drilled 298' Depth Cased 298'

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 298 Feet
Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8"	12.92	.188	+2'	298'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 258 Feet to 298 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50'
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 298 Feet

9. WATER LEVEL
Static Water Level 90 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2189
Signed [signature]
By driller performing actual drilling on site or contractor
Dated Nov 22 2006

RECEIVED
2006 NOV 28 AM 10:51
STATE ENGINEERS OFFICE