


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57810

1. OWNER Tom Spencer
 MAILING ADDRESS 5304 Santa Teresa Ave.
Santa Rosa, CA 95409

ADDRESS AT WELL LOCATION 418 Day Lane Wellington
NV.

2. LOCATION SE 1/4 SW 1/4 Sec. 1 T 11N
 PERMIT NO. SW SE 010-211-24
Issued by Water Resources Parcel No.

N/S R 23E E Lyon County
 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Coarse brown sand		0	30	30
Brown clay		30	40	10
Coarse brown sand		40	110	70
Coarse gray sand		110	120	10
Gray sand		120	140	20
Gray sandy clay		140	220	80
Gray sand and gravel	x	220	260	40
NAD 83 N 38.84113 W 119.35573				
<u>38.841218 N</u> <u>119.354732 W NAD 83</u>				

8. WELL CONSTRUCTION

Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 260 Feet
10 5/8 Inches 0 Feet 260 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>260</u>

Perforations:
 Type perforation Machine cut
 Size perforation 3/32 x 3
 From 220 feet to 260 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 260 feet

9. WATER LEVEL

Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Bruce MacKay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 11/9/2006

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>500</u>	<u>STATE ENGINEERS OFFICE</u>	<u>3</u>
	<u>2006 NOV 22 AM 10:57</u>	
	<u>RECEIVED</u>	