

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52025

1. OWNER Victor Gonzales ADDRESS AT WELL LOCATION None established  
 MAILING ADDRESS 1200 Louisiana 2759 Indiana Ave  
Last Chance Ranch, Unit 3, Elko NV 89801

2. LOCATION N 20 1/4 NW 1/4 Sec 7 T 34 R 36 Co Elko County  
 PERMIT NO. N/A Issued by Water Resources Parcel No. 032-007-022 Subdivision Name Last Chance Ranch Unit 3 Block 6, Lot 22

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sandy clay</u>		<u>0</u>	<u>21</u>	<u>21</u>
<u>Sand</u>		<u>21</u>	<u>22</u>	<u>1</u>
<u>Clay</u>		<u>22</u>	<u>27</u>	<u>5</u>
<u>Clay, sand, gravel boulders</u>		<u>27</u>	<u>39</u>	<u>12</u>
<u>Cased off with 10" casing to 41</u>				
<u>Decomposed grey shale</u>		<u>39</u>	<u>125</u>	<u>86</u>
<u>Blue clay or silt shale</u>		<u>125</u>	<u>242</u>	<u>117</u>
<u>Fine black sand</u>	<u>uv</u>	<u>242</u>	<u>255</u>	<u>13</u>
<u>Grey shale</u>		<u>255</u>	<u>260</u>	
<u>* Surface seal</u>				
<u>Hole plug 52 back to 42</u>				
<u>Hole then filled with bentonite grout from 42 to surface - 10" casing then pulled - grout dropped to 25 ft</u>				
<u>25 to surface cement grout</u>				
<u>G.P.S. 40-85361 N</u>				
<u>115-713724</u>				
<u>476</u>				
<u>NAD 22</u>				

8. WELL CONSTRUCTION

Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>12</u>	<u>0</u>	<u>39</u>
<u>10</u>	<u>39</u>	<u>52</u>
<u>8</u>	<u>52</u>	<u>260</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+3</u>	<u>260</u>

Perforations:  
 Type perforation Touch cut  
 Size perforation 1/2 x 4

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 224 feet to 254 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

\* Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Bentonite & hole plug  
 Gravel Packed:  Yes  No  
 From 52 feet to 260 feet

9. WATER LEVEL

Static water level 64 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature Cold °F Quality Fair

Date started 7-12-06, 19\_\_\_\_  
 Date completed 10-24-06, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>17</u>	<u>25</u>	<u>1 hr</u>
	<u>66:11:00</u>	<u>91 ACN 9007</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Muth Drilling Co. Contractor  
 Address 203 Pine St Contractor  
Elko, NV 89801

Nevada contractor's license number issued by the State Contractor's Board 10819  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632

Signed James R. Muth  
 By driller performing actual drilling on site or contractor  
 Date 11-10-06