COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102277
Permit No.
Basin 212

NOTICE OF INTENT NO. 30791

1. OWNER KRYSTLE TOWERS LLC
MAILING ADDRESS 2827 PARADISE RD
LAS VEGAS, NV 89109

ADDRESS AT WELL LOCATION 2845 S LAS VEGAS BLVD
LAS VEGAS, NV

2. LOCATION SE ¼ NE ¼ Sec 09 T 21 S R 61 E CLARK County

PERMIT NO. DW1234 (Issued by Water Resources) | 162-09-704-001 (Parcel No.) | Fontainebleau (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE (DEWATER)
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 44 Dewater wells | | | | |
| Depth 40' | | | | |
| Brown dirt & rock | | 0 | 14' | 14' |
| Moist dirt & rock | x | 14' | 17' | 3' |
| White silty clay | | 17' | 19' | 2' |
| Brown silty clay | | 19' | 32' | 13' |
| Caliche | | 32' | 34' | 2' |
| Brown clay | | 34' | 40' | 6' |

Date started 12/14, 20 06
Date completed 1/3, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 40 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |

Perforations:
Type perforation Machine
Size perforation 1/4"x2.5" long 16 around
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161
Signed
By driller performing actual drilling on site or contractor
Date January 18, 2007

RECEIVED JAN 28 2007



Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com