

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30881

1. OWNER John and Julie Shock ADDRESS AT WELL LOCATION 2331 Pinto Ln  
 MAILING ADDRESS 2331 Pinto Ln Las Vegas NV 89107  
 2. LOCATION NW 1/4 SE 1/4 Sec. 32 T. 20 N. R. 61 E Clark County  
 PERMIT NO. 74238/74239 139-32-702-014 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	2	2
Loose Gravel		2	4	2
Dirt & Clay		4	18	16
Cemented Gravel		18	36	18
White Clay & Gravel		36	193	157
Cemented Gravel		193	230	37
Red and White Clay		230	356	126
Gravel		356	400	44

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 400 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		PVC	0	400
		Factory		

Perforations:  
 Type perforation Factory  
 Size perforation \_\_\_\_\_  
 From 300 feet to 400 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 21 feet below land surface  
 Artesian flow No G.P.M. 150 P.S.I.  
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name T. O. C. Well Drilling & Pump Contractor  
 Address 2870 W. Pebble Rd Contractor  
Las Vegas NV. 89123  
 Nevada contractor's license number issued by the State Contractor's Board 59948  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 01-19-07

Date started (Per State Plans) 1-12, 2007  
 Date completed 1-20, 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>150</u>		