

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 102450
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30195

1. OWNER Batista ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4170 W. Magnet 4170 W. Magnet
Pahrump, NV 89048

2. LOCATION NE 1/4 NE 1/4 Sec. 26 T 20S N/S R 52E E Nye County
 PERMIT NO. 28-603-07 Vegas Acres
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown loam		0	4	4
grey loam		4	38	34
green clay		38	51	13
grey clay		51	62	11
grey caleche		62	65	3
green clay	x	65	91	26
grey caleche	x	91	96	5
grey clay	x	96	119	23
grey caleche	x	119	122	3
grey clay	x	122	126	4
See next line	x	126	195	69
brown clay with caleche stringers				
brown clay and gravel	x	195	200	5

DCNR/DWR
 RECEIVED

FEB 26 2007

LAS VEGAS OFFICE

Date started 2/7/1907 2007 19
 Date completed 2/7/1907 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 160 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources On-site driller 2086
 Signed _____ By driller performing actual drilling on-site or contractor
 Date 1-16-07