39.29955N/118.531083W

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102508
Permit No.
Basin 101

NOTICE OF INTENT NO. 54160

1. OWNER JKC Building
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5555 Cybab/Hyden (Lot 46) Fallon, NV

2. LOCATION SE ¼ NW ¼ Sec. 20 T. 19 N/S R. 28 E County
PERMIT NO. (Issued by Water Resources) 008-173-06 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	26	
Clay		26	37	
Sand Coarse		37	59	
Brown Brown				
Grey Clay	59'		76	
Black Sand				
Brown Sand		76	107	
Gravel				
Clay Blonde		107	112	
Blond Sand Gravel		112	122	
Grey Black Clay		122	140	
Blond Sand Gravel				
(W Some Gray				
Sand to pea				
39.499250 N				
118.868467 E NAD83				

Date started 10/23/06, 20
Date completed 10/24/06, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2½

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 5/8	13	1.88	1	20
6 5/8	PVC	SH40	20	140

Perforations:
Type perforation Machine Slot
Size perforation 1/8 x 4 x 8th Rows per
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 27 ft feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor)
Address P.O. 338 (Contractor)
39 N. 83428
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed (By driller performing actual drilling on site or contractor)
Date 10/31/01

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627