WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102517
Permit No.
Basin 162

NOTICE OF INTENT NO. 30507

1. OWNER MICHAEL DIERRICO
MAILING ADDRESS 6210 S JANE AVE
PAHRUMP,NV, NV

ADDRESS AT WELL LOCATION 6210 S JANE AVE

2. LOCATION NE 1/4 NW 1/4 Sec. 17 T 21S N/S R 54E E NYE County
PERMIT NO. Issued by Water Resources
45-171-47 Parcel No
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	15	15
CALICHE		15	21	6
CLAY		21	45	24
CALICHE		45	65	20
CLAY		65	76	11
CALICHE	WB	76	79	3
CLAY		79	105	26
CALICHE	WB	105	120	15
CALICHE	WB	120	150	30
CLAY		150	180	30
CALICHE	WB	180	200	20

DCNR/DWR
RECEIVED
APR 0 6 2007
LAS VEGAS OFFICE

Date started 4/2/2007
Date completed 4/2/2007

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From 100	feet to	120	feet
From 140	feet to	160	feet
From 180	feet to	200	feet
From	feet to		feet
From	feet to		feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor
Address 1220 E MANSE RD
Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed
By driller performing actual drilling on-site or contractor
Date 4/3/2007

USE ADDITIONAL SHEETS IF NECESSARY