WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102532
Permit No.
Basin 212

NOTICE OF INTENT NO. 31015

1. OWNER M. Holding LLC
MAILING ADDRESS 222 Via Marnell Way Las Vegas, NV 89119
ADDRESS AT WELL LOCATION 12290 Rancho Destino Rd, Las Vegas

2. LOCATION SE ¼ NW ¼ Sec. 09 T. 23 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) 191-09101-014 Parcel No. DSB Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pulled system from the well				
Abandoned 8" well to 495' Depth.				
Existing perforations from 495' to 388'				
Perforated casing from 388' to 155'				
Pumped 6.5 yards of neat cement through a tremmie hose from the bottom of the well to 22' from the top of the well.				
Poured concrete grout from 22' to the surface completely filling well.				
FUNDED BY NDWR Uniq PLUG 68345				

Date started 1/10/ 2007
Date completed 4/2/ 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 495' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"				

Perforations:
Type perforation
Size perforation
From 388 feet to 495 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 206' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T-D-C Drilling (Contractor)
Address 2870 W Pebble Rd (Contractor)
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on site driller 2316
Signed (By driller performing actual drilling on site or contractor)
Date 04-02-2007

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

10-623