WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

C0360 1P

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

4 WELLS

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 10261 6
Permit No
Basin 212

NOTICE OF INTENT NO 30679

1. OWNER Rose Pelino
MAILING ADDRESS 6 Sylvan Way
Parsippany NJ

ADDRESS AT WELL LOCATION 5164 Rock A Car Rd
Las Vegas NV

2. LOCATION SE ¼ NW ¼ Sec. 27 T. 21 N/S R. 61 E. Clark County

PERMIT NO. Issued by Water Resources | Parcel No. 162-27-201-005 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0.0	0.2	0.2
Type II		0.2	1.0	0.8
Silty Clay		1.0	11.0	10.0
Caliche		11.0	13.0	2.0
Sandy Clay		13.0	23.5	10.5
Silty Sand		23.5	65.0	41.5

MAP DATUM
WGS 84

MW-45B 36° 05.817 N 115° 08.956 W
MW-45C 36° 05.818 N 115° 08.955 W
MW-46B 36° 05.838 N 115° 08.734 W
MW-46C 36° 05.839 N 115° 08.733 W

Date started 3/14 2007
Date completed 3/21 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 65/25 Feet Depth Cased 65/25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 1/2 Inches	0.0 Feet	65.0 Feet
8 1/2 Inches	0.0 Feet	25.0 Feet
8 1/2 Inches	0.0 Feet	30.0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0		Sch 40 PVC	0.0	65.0
2.0		Sch 40 PVC	0.0	25.0
2.0		Sch 40 PVC	0.0	30.0

Perforations:
Type perforation Machine Slot
Size perforation .020
From 65.0 feet to 60.0 feet
From 25.0 feet to 20.0 feet
From 30.0 feet to 25.0 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 65 / 25/30 feet to 58 / 18/23 feet

9. WATER LEVEL
Static water level 23.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services LLC
Contractor
Address 7150 Placid St.
Contractor
Las Vegas Nv. 89119

Nevada contractor's license number issued by the State Contractor's Board 57266

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272

Signed
By driller performing actual drilling on site or contractor
Date 3/21/07

USE ADDITIONAL SHEETS IF NECESSARY