COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 10d663
Permit No.
Basin 103

NOTICE OF INTENT NO. 58228

1. OWNER CORNERSTONE CONSTRUCTION
MAILING ADDRESS P.O. BOX 22270
CARSON CITY, NV 89721

ADDRESS AT WELL LOCATION 13220 SENECA RD
STAGECOACH, NV

2. LOCATION SW ¼ NE ¼ Sec 12 T 17 N R 22 E LYON County

PERMIT NO. NE SE (Issued by Water Resources) | 15-322-14 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BOULDERS & COBBLE		0	29	29
VOLCANIC GRAVELS		29	160	131
HARD BLACK VOLCANIC W/ GLAY		160	220	60
HARD VOLCANIC FRACTURES GRAVELS	XXX	220	260	40

GPS INFO:
39.35023*N
119.45714*W NAD 83

Date started 11/10, 20 06
Date completed 11/17, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	85	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	120 Feet
9 7/8 Inches	120 Feet	220 Feet
6 1/8 Inches	220 Feet	260 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	220
5 9/16	11.85	.188	210	260

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3X3/32
From 200 feet to 220 feet
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to ~~220~~ 260 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 11/29/06