WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
086702
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

3 wells

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102678
Permit No.
Basin 212

NOTICE OF INTENT NO. 28902

1. OWNER Mission Industries
MAILING ADDRESS One W. Mayflower
N. Las Vegas NV

ADDRESS AT WELL LOCATION
1001 S. 1st Street
Las Vegas NV

2. LOCATION SW ¼ SW ¼ Sec. 34 T. 20 N/S R. 61 E. Clark County
PERMIT NO. ____ Issued by Water Resources | 139-34-401-011 Parcel No. | ____ Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Concrete		0.0	0.9	0.9
Type II		0.9	2.0	1.1
Silty Clay		2.0	7.0	5.0
Weak Caliche		7.0	11.0	4.0
Clay Silty Clay		11.0	25.0	14.0

Map Datum
WGS 84

MW-4 36°09.588N 115°09.085W
MW-5 36°09.581N 115°09.101W
MW-6 36°09.614N 115°09.113W

Date started 4/12 2007
Date completed 4/12 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8½ Inches	0.0 Feet	25.0 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0		Sch 40 PVC	0.0	25.0

Perforations
Type perforation Machine Slot
Size perforation .020
From 25.0 feet to 10.0 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25 feet to 8 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services LLC
Contractor
Address 7150 Placid St.
Contractor
Las Vegas NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2273
Signed [signature]
By driller performing actual drilling on site or contractor
Date 4/16/07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY