

39.36.417N 119 16.106 W

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 102755
Permit No. 1076
Resin.

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56187 56185 56189 5678

1. OWNER Dale's Structure ADDRESS AT WELL LOCATION 915 Truckee Lane
 MAILING ADDRESS NC Fernley, NV

2. LOCATION 10 1/2 1/4 NE 1/4 Sec. 15 T. 20 N. R. 24 E. County ...
 PERMIT NO. 20261-04 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drilling to 160' no available strata for non filtered bore hole				
Abandoned				
performed from 1-80' 1/8" x 2" x 4# holes w/ holes perforator				
pump approximately 4 yards of 12" or greater diameter from 160 to surface				
let settle 12 hrs. next cement from 20' to surface				
Sand		80	160	
Mechanical Seal				

8. 160 WELL CONSTRUCTION
 Depth Drilled 80 Feet Depth Cased N/A 80' Feet

HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches To 80 Feet
 From 110 Feet To 160 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/8</u>	<u>At</u>	<u>Surface</u>		

Perforations:
 Type perforation On Reamer
 Size perforation 1/8" x 2" x 4# holes
 From Surface feet to 80 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal Unknown

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From feet to feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

Date started 11/16/06, 20.....
 Date completed 11/16/06, 20.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name [Signature] Contractor
 Address Fernley Drill Inc Contractor
PO Box 88 NV 89425
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1870

Signed [Signature] By driller performing actual drilling on site or contractor
 Date 11/13/06

RECEIVED
2006 DEC -8 AM 11:06
STATE ENGINEERS OFFICE

N 39.607056
W 119.267442 NAD 83