

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56522

1. OWNER Al Park Petroleum ADDRESS AT WELL LOCATION 501 Front St
MAILING ADDRESS P.O. 1600 Elko NV 89802 Battle Mt NV

2. LOCATION NW 1/4 NE 1/4 Sec 20 T 32 S R 45 E Lander County
PERMIT NO. NDEPS-004324 Issued by Water Resources Parcel No. 002-18005 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------------|--------------|-----------|------------|------------|
| <u>dark grey sand silt</u> | | <u>0</u> | <u>7'</u> | <u>7'</u> |
| <u>sand</u> | <u>wet</u> | <u>7'</u> | <u>15'</u> | <u>8'</u> |
| <u>498516.442 m Northing</u> | | | | |
| <u>506033.554 m Easting</u> | | | | |
| <u>UTM 11 north</u> | | | | |
| <u>NAD 83</u> | | | | |
| <u>N40.639372</u> | | | | |
| <u>W 116.929648 NAD27</u> | | | | |
| 2006 OCT 30 PM 2:23 | | | | |

8. WELL CONSTRUCTION
Depth Drilled 15' Feet Depth Cased 15' Feet

HOLE DIAMETER (BIT SIZE)
From 8" Inches To 1.5 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2"</u> | | <u>SCH 40</u> | <u>0</u> | <u>5'</u> |

Perforations:
Type perforation Feeding Slot
Size perforation .020
From 5 feet to 15 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
Depth of Seal 4 Neat Cement
Placement Method: Pumped barite chip Cement Grout
 Poured 4-4 1/2 Hydrated Concrete Grout

Gravel Packed: Yes No
From 4 1/2 feet to 15' feet

9. WATER LEVEL
Static water level 7 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 85 °F Quality _____

Date started Sept 11, 2006
Date completed Sept 11, 2006

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|--------|-------------------------------|-------------------|
| <input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | <u>none</u> | <u>25 minutes</u> |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Har Tech Drilling Contractor
Address P.O. 940 Mendocino Rd 83042 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2312

Signed [Signature] By driller performing actual drilling on site or contractor
Date 10/25/06