


Log No. 10d773

Permit No. _____

Basin. 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56919

1. OWNER Al Park Petroleum ADDRESS AT WELL LOCATION Chris Sheeran Way
MAILING ADDRESS P.O. Box 1600 EIKO NV 89803 Near intersection of Idaho St

2. LOCATION SW 1/4 SW 1/4 Sec. 11 T. 32 N. R. 55 E. EIKO County
PERMIT NO. NDEP 6-00009 City right of way Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	6"	6"
sandy silt brown		6"	10'	4 1/2'
dark brown clay		10'	15'	5'
gravelly sand silt		15'	19'	4'
yellow clayey silt		19'	30'	11'
gravelly sand dark gray		30'	35'	5'
yellow brown silty clay		35'	43'	8'
yellow brown gravelly sand		43'	50'	7'
dark brown silty clay	W e l l	50'	55'	5'
yellow brown sand		55'	65'	10'
dark brown clayey silt		65'	68'	3'
dark brown sandy silt		68'	72'	4'
gravelly sand		72'	75'	3'
N40.842391				
W 115.751524 NAD27				
4521999.655m Northing				
605173.158m Easting				
UTM <u>12</u> North				
NAO <u>83</u>				

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)
From 8 Inches To 75 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>SCH 40</u>	<u>0</u>	<u>55</u>

Perforations:
Type perforation Factory slot
Size perforation 0.20
From 55 feet to 75 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 51' Neat Cement
Placement Method: Pumped Bentinite Cement Grout
 Poured Chips from 54'-51' hydrated Concrete Grout
Gravel Packed: Yes No
From 54' feet to 75' feet

9. WATER LEVEL
Static water level 55' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 85 °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Har Tech Drilling Contractor
Address P.O. 940 Madison Id 83642 Contractor

Date started Sept 8, 2006
Date completed Sept 8, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>3</u>	<u>6'</u>	<u>30 minutes</u>

Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2312
Signed A. DeLoach
By driller performing actual drilling on site or contractor
Date 10-15-06