COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

[redacted] OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102776
Permit No.
Basin 107

NOTICE OF INTENT NO. 58225

1. OWNER DAVE BAMMER CONSTRUCTION
MAILING ADDRESS 1420 INDUSTRIAL WAY UNIT # 2
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 733 UPPER COLONY RD
WELLINGTON, NV 89444

2. LOCATION ~~NW~~ ¼ ~~NE~~ ¼ Sec 34 T 12 N R 23 E LYON County
PERMIT NO. NE NW (Issued by Water Resources)
010-081-29 (Parcel No.)
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	5	5
BROWN CLAY		5	26	21
DG SANDS AND CLAY		26	75	49
GRAY CLAY DRY		75	129	54
GUMMY GRAY CLAY		129	173	44
SMALL CLAY STATAS		173	212	39
SMALL GRAVELS				
GREEN SANDS				
COLORED SANDS				
[redacted]Y CLAY	XXX	212	240	28
N 38.666755				
W 119.353425				
NAD27				
GPS INFO:				
38.86666*N NAD83				
119.39444*W				

Date started 10/16, 20 06
Date completed 10/18, 20 06

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	65	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdsr21	4.06	.216	20	240

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 240 feet

9. WATER LEVEL
Static water level 78' feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane (By driller performing actual drilling on site or contractor)
Date 10/28/06

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429