WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102782
Permit No.
Basin 207

NOTICE OF INTENT NO. 56046

1. OWNER Mike Kilmer
MAILING ADDRESS 27149 Calendula St. Corona CA. 92883

ADDRESS AT WELL LOCATION Parcel C Sew mill Road
NAD27 - N38.88568 W 115.00891

2. LOCATION NW ¼ SE ¼ Sec 21 T. 12 N/S R. 62 E. White Pine County

PERMIT NO. N/A Issued by Water Resources | 13-088-03 Parcel No. | none Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty top Soil		0	2	
gravel clay conglomerate		2	42	
Clay silt		42	76	
gravel clay con		76	81	
Clay Silt		81	93	
gravel	water	93	99	6'
clay		99	101	
gravel	water	101	107	6
clay		107	117	
gravel	water	117	123	6'
clay		123	138	
gravel	water	138	144	6"
clay		144	150	

Date started Sept 18, 2006
Date completed Oct 11, 2006

7. WELL TEST DATA

TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	5	1 hr

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 Inches	50 Feet	120 Feet
6 Inches	120 Feet	150 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	150

Perforations:
Type perforation mill
Size perforation 1/2 2.5" x 6 row
From feet to feet
From feet to feet
From 100 feet to 120 feet
From 130 feet to 150 feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 115 feet

9. WATER LEVEL
Static water level 88 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling (Contractor)
Address Po Box 64 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 047226

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Jason Maynard (By driller performing actual drilling on site or contractor)
Date Oct 24-06

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627