



STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 102791
Permit No. _____
Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58458

1. OWNER **Jimmy Mohammad** ADDRESS AT WELL LOCATION **1170 East National**
MAILING ADDRESS **PO Box 1653** **Winnemucca, Nv 89446**

2. LOCATION NW 1/4 NW 1/4 Sec 20 T36 N/S R38E Latitude 40° 59.322' UTM E NAD 27
PERMIT/WAIVER NO. _____ D-1 Longitude 117° 44.038' N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____ Subdivision Name: _____ County: **Humboldt**

3. WORK PERFORMED New Well Replace Recondition
 Deepen Other _____ 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand Gravel		0	30	30
Gravel & Cobles		30	105	75
Boulders		105	110	5
Cobles & Sand		110	130	
Sand		130	135	5
Cobles & Sand		135	180	45
Clay		180	185	5
Course sand & fine gravel	X	185	215	
Clay		215	220	
Sand	X	220	230	

40,988612
N 117.732998 NAD22

9. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
10 5/8 Inches _____ 0 Feet _____ 230 Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4.06	.316	20	230

Perforations:
Type of perforation **Factory cut slots**
Size of perforation 050
From 200 feet to 230 feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 0 to 100 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
Gravel Pack: Yes No 100 to 230 Pumped Poured
Type: 3/8
Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

Date started: **October 5, 20 06**
Date completed: **October 8, 20 06**

7. Water Level
Static water level: 47' feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: cool °F
Quality: fair

8. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailor	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
60		4	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Fred Anderson Drilling**
(CONTRACTOR)

Address **10760 S. Grass Valley Road**
(CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board **21467**
Nevada driller's license number issued by the Division of Water Resources / the on-site driller **2083**

Signed _____
By driller performing actual drilling on site or contractor
Date **October 30, 2006**