Amended.

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102796
Permit No. 39845
Basin 212

NOTICE OF INTENT NO. 30875

1. OWNER M · Holdings LLC
MAILING ADDRESS 222 Via Marnell Way
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION 12375 Gilespie St, Las Vegas

2. LOCATION SE ¼ NW ¼ Sec. 9 T. 23 N/S R. 61 E. Clark County
PERMIT NO. 39845 (Issued by Water Resources) 191-09-201-011 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic QM ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Status	From	To	Thickness
Fished out system from bottom of the well and removed system from well completely. Abandoned 8" well to 600' Depth. Existing perforations from 400' to 600' perforated casing with mill knife perforator from 400' to 260' Pumped in 15 yards of cement grout through a tremmie hose from the bottom of the well to the top, completely filling well. 100 feet of 1¼ galvanized tremmie pipe was left in the well above the the static water level and incorrect material used in plugging well. Drilled out cement grout and 100 ft of tremmie pipe from well, from surface to 600' Depth. Pumped in 8 yards of neat cement through a tremmie hose from the bottom of the well to the surface completely filling the well.				

Date started 1-4- 2007
Date completed 4-16- 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)
Inches From Feet To Feet
Inches From Feet To Feet
Inches From Feet To Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations: plugging of 109 22153
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 314' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C. Drilling (Contractor)
Address 2870 W Pebble Rd (Contractor)
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2267
Signed (By driller performing actual drilling on site or contractor)
Date 4/16/07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

.01-627