Amended

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102797
Permit No. 65497
Basin 212

NOTICE OF INTENT NO. 30873

1. OWNER M. Holdings LLC
MAILING ADDRESS 222 Via Magnell Way, Las Vegas NV
ADDRESS AT WELL LOCATION 170 Lemley St, Las Vegas

2. LOCATION SE ¼ NW ¼ Sec. 9 T. 23 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) 191-09-201-010 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Quasi Municipal
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pulled system completely from the well.				
Abandoned 8" well to 400' Depth.				
Existing perforations from 305' to 400'				
Perforated casing with Mill Knife perforator from 305' to 265'				
Pumped in 9 yards of cement grout through a tremmie hose from the bottom of the well to the surface completely filling the well.				
100 feet of galvanised tremmie pipe was left in the well above the static water zone and incorrect plugging material was used.				
Drilled out cement grout and 100' of galvanised tremmie pipe from the well. From the surface to 400' Depth.				
We pumped in 8 yards of neat cement through a tremmie hose, from the bottom of the well, to the surface, completely filling the well.				

Date started 1/11/2007
Date completed 1/30/2007

7. WELL TEST DATA
TEST METHOD ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

MAY 01 2007
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8				

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 315' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C. Drilling (Contractor)
Address 2870 W Pebble Rd, Las Vegas NV 89123 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2267
Signed (By driller performing actual drilling on site or contractor)
Date 5/1/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627