Amended

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102798
Permit No.
Basin 212

NOTICE OF INTENT NO. 30876

1. OWNER M. Holdings LLC
MAILING ADDRESS 222 Via Marnell Way, Las Vegas NV 89
ADDRESS AT WELL LOCATION 165 Lemley St, Las Vegas NV

2. LOCATION S.E. ¼ N.W. ¼ Sec. 09 T. 23 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 191-09-201-020 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed system from the well Completely. Abandoned 8" well to 500' Depth. Existing perforations from 500' to 325' Perforated casing with mill knife perforator from 325' to 269' Pumped in 12.5 yards of cement grout through a tremmie hose from the bottom of the well to 80' from the surface. We left 100' of galvanised tremmie pipe in the well. We poured concrete grout from 80' to the surface, completely filling the well. Incorrect Plugging material used to seal this well. Drilled out cement grout and 100' of galvanised tremmie pipe from the well. From 500' to the surface. We pumped in 8 yards of neat cement through a tremmie hose, from the bottom of the well to the surface, completely filling the well.				

Date started 1/11/2007
Date completed 4/30/2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

MAY 01 2007

8. WELL CONSTRUCTION
Depth Drilled 500' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 R				

Perforations: plugging of log 53459
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 319' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T-D-C Drilling Contractor
Address 2870 W Pebble Rd Contractor
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2267
Signed By driller performing actual drilling on site or contractor
Date 5/1/07

(Rev. 12/01) USE ADDITIONAL SHEETS IF NECESSARY (0-427)