


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 102891  
 Permit No. \_\_\_\_\_  
 Basin 858

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK



Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **57803**

1. OWNER **Sandy Barrick** ADDRESS AT WELL LOCATION **5360 Cedarwood Dr.**  
 MAILING ADDRESS **5360 Cedarwood Dr.**  
**Reno, NV 89511**

2. LOCATION **SW 1/4 NE 1/4 Sec. 2 T 17N N/S R 19E E Washoe** County  
 PERMIT NO. **DOM 06-022** Parcel No. **045-573-14** **Mountain Meadows #1** Subdivision Name  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  
 Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **Mud**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & gravel		126	133	7
Brown sandy clay		133	163	30
Soft zone		163	166	3
Brown sandy clays		166	204	38
Soft zone		204	210	6
Sand & gravels with some clay		210	238	28
Cemented boulder		238	249	11
Brown sandy clays with gravels		249	292	43
Brown sandy clay		292	309	17
Soft zone		309	315	6
Multi color volcanic rock		315	350	35
Soft zone	X	350	361	11
Multi color volcanic rock	X	361	370	9
Brown sandy clays		370	374	4
Sand some gravel with streaks of clay	X	374	400	26

Washoe County Permit # WL060220  
 NAD 83  
 N 39.37006  
 W 119.81501

2007 FEB -5 PM 1:01  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled **400** Feet Depth Cased **400** Feet

HOLE DIAMETER (BIT SIZE)  
 From **6 1/8** Inches To **125** Feet  
 From **125** Feet To **400** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>5</b>	<b>10.79</b>	<b>.188</b>	<b>110</b>	<b>400</b>

Perforations:  
 Type perforation **Machine cut**  
 Size perforation **3/32 x 3**  
 From **350** feet to **390** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level **89** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **Cool** °F Quality **Not tested**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Bruce MacKay Pump & Well Service, Inc.** Contractor  
 Address **1600 Mt. Rose Hwy** Contractor  
**Reno, NV 89511**  
 Nevada contractor's license number issued by the State Contractor's Board **23096**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **923**  
 Signed **R. Bruce MacKay**  
 By driller performing actual drilling on-site or contractor  
 Date **1/19/2007**

Date started **1/10/2007**, 19  
 Date completed **1/18/2007**, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift G.P.M. <b>15</b>		<b>3</b>

N39.370167  
 W 119.814006 NAD83