WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102897
Permit No.
Basin 203

NOTICE OF INTENT NO. 30118

1. OWNER Dale Wallis
MAILING ADDRESS P.O. Box 125 Caliente NV 89008
ADDRESS AT WELL LOCATION 2 miles East on Beaver Dam RD 3/4 mile North 3 miles North of Caliente

2. LOCATION NW ¼ SE ¼ Sec. 14 T. 3 N. R. 67 E. Lincoln County
PERMIT NO. 0 (Issued by Water Resources) 013-170-30 (Parcel No.) Meadow Valley Estates (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	6	6
Hard Clay-gravel		6	60	54
Sand-gravel	X	60	70	10
Hard Clay-Boulders		70	140	70
gravel-sand	X	140	172	32
Hard Clay-Boulders		172	180	8

GPS N37° 41.643'
W 114° 27.012'
Datum WGS 84

Date started 4-27-07, 20
Date completed 4-29-07, 20

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
90		2

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2	PVC	Sch 40	0	180

Perforations:
Type perforation Saw cut
Size perforation 1/8 x 3"
From 40 feet to 100 feet
From 120 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50' feet to 180 feet

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60.1 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 59 Hiko NV 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1181
Signed (By driller performing actual drilling on site or contractor)
Date 4-29-07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(09-02)