WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102931
Permit No.
Basin 102

NOTICE OF INTENT NO. 56945

1. OWNER Andrew Spence
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1020 W. 9th St Silver Springs NV 89429

2. LOCATION ~~S/2~~ ¼ SE ¼ Sec. 13 T. 17N N/S R. 24 E. Lyon Co, County
PERMIT NO. / Issued by Water Resources | 017-264-10 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt, Cobbles & Silt,		0	23'	23
Gray clay		23	46	24'
Broken Basalt and clay		46	140	94'
Volcanic Rock		140	190	50'
Fractured Basalt		190	220	30'
N 39.332801 W 119.230946 NAD27		[redacted]		
Gps. 39° 19.962 N 119° 13.916 W			WGS84	

Date started Feb 23 /07, 20
Date completed Feb 26 /07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30 Gpm.		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	220'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 5/8	.131b	.188	+1	20'
10 5/8	PVC	SDR 21	20	220'

Perforations:
Type perforation Sawed
Size perforation 1/8 x 4" 4 Power
From 180' feet to 220' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 220' feet

9. WATER LEVEL
Static water level 68' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc, Contractor
Address PO Box 599 Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel L Leach
By driller performing actual drilling on site or contractor
Date March 3 /07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627